

## CV AUDIO TESTING

### PAT TEST

15.06.18

### STEAMCHICKEN

The following equipment was tested today and found to comply with electrical standards under the Health and Safety "Electricity at Work Regulations" 1989 No. 635.

Tests carried out:

1. Visual test of plugs, leads and fuses.
2. Earth continuity test - resistance of earth between earth pin and earth points on appliance less than 0.1 ohms
3. Insulation resistance test - resistance between current conductors and earth more than 2 Megohms.

PLEASE NOTE: The above apply to all Class I appliances. Class II appliances are double insulated and do not normally have an earth connector. Class III appliances are low voltage devices supplied by isolating transformers and are not normally earthed.

Class	Make	Model No	Serial No	Description	Pass
I	Soundtech	PS802	9710C065	Power amp	PassJun18
II	Roland	RD170	ZQ90775	Keyboard	PassJun18
I	Soundtech	PL200	2092986A	Power amp	PassJun18
I	Power Plant	None	None	Pedal board	PassJun18
I	Laney	CXP110	SJC1329	Pow/monitor	PassJun18
I	Laney	CP10	KFB3046	Pow/monitor	PassJun18
I	Behringer	Europower PMP2000	S0808835611	Mixer amp	PassJun18
I	Yamaha	PAS300	Not visible	Amp module	PassJun18
I	13amp/IEC	Kettle leads			PassJun18
I	13amp/13amp	Ass'd mains leads			PassJun18

TESTED AS ABOVE

15.06.18

Graham Bradshaw  
CV Audio